CNA Environmental, LLC

27 Kent Street

N.Y. ELAP#: 11534

Federal ID# 14-1777367

ISO 11731:1998

Page 1 of 1

Phone: (518) 884-0800

Ballston Spa, NY 12020

Lab Sample #: **F008254**Date Reported: 11/21/17

Analysis Report For:

Water Wise

75 Bermar Park Suite 5 Rochester, NY 14624

Site Sampled: Lindsay House

East Ave Rochester, NY Origin: Lindsay House

Description: NPW

Date/Time Collected: 10/26/17 09:20 Collected By: Chris Gienau

Date/Time Received: 10/27/17 11:00 14.3°C

E-mail: mbromley@waterwiseofamerica.com

Sample ID	Analysis <u>Performed</u>	<u>Method</u>	Date & Time <u>Analyzed</u>	Final Result	<u>Units</u>	Amount of Sample Examined	Cl ⁻ Result	Sample Point- Biocide Used
01	Legionella spp.	ISO 11731	10/30/17 12:35	Non-Detect Non-Detect	cfu/ml cfu/ 100 ml	4.0 ml	0.05 mg/l	Sump <i>Chlorine, H2O2</i>

Notes: The minimum detection limit is equal to 0.25 cfu/mL; 25 cfu per 100 mL. Different minimum detection limits and amount of sample examined reflect different sample types and methods run by laboratory.

A Non-detect result is equivalent to a final result of <0.25 cfu/ml and <25cfu/100ml.

Emity a Statuty

cfu - colony forming unit

Technical Director:

The information in this report is accurate to the best of our knowledge and ability. In no event shall our liability exceed the cost of these services.